

Study on calculating pollution equivalent of electric heating with heat storage technology accommodating wind based on LCA

Electric heating with heat storage technology can effectively reduce the abandoned wind of wind farms located in north China during the winter, improving the consumptive capacity of wind power. Considering the poor economy and singleness of electric heating with heat storage technology, life cycle assessment method is applied to analyze each stage of electric heating boiler with heat storage technology, including production, transportation, construction, operation and dismantling scrap. Meanwhile, the pollution emissions of each stage are calculated and compared to the cogeneration of heat and power in order to analyze its superiority and expandibility. The research result shows that the electric heating with heat storage technology consuming abandoned wind will reach a obviously lower pollutant discharge level than cogeneration heating mode. Therefore, from the point of environmental protection, electric heating with heat storage technology has extensive popularization significance in north China where abandoned wind phenomenon is serious.

Keywords: Wind power; electric heating with heat storage; pollution discharge; life cycle assessment

Introduction

According to the law of wind power generation, the night is the best stage of the wind power output in northern China, contrary to the power load. Considering the security and stability of power grid system, a large number of wind have to be abandoned, especially in the northeast of China during the period of winter heating [1]. On the basis of the wind power industry test statistics from National Energy Bureau, the rate of national abandoned wind was 8% in 2014, less than 7% of the next year, running up to 21% in the first half of 2016. The figures of 2015 indicated different rates of abandoned wind in different provinces, 39% in Gansu, 32% in Xinjiang, 32% in Jilin, 21%

Messrs. Weijun Wang, Weisong Peng, Wei Luo, Department of Economic Management, University of North China Electric Power, Hebei Baoding 071000, China, and Yong Sun, State Grid Jilin Electric Power Co., Ltd, Jilin Changchun 130000, China. Corresponding author: wwjmodchg@126.com

in Heilongjiang, 18% in Inner Mongolia, 13% in Ningxia, 10% in Hebei. In 2015, the approach of winter made the abandoned wind rate of wind power project up to 60%, including Gansu, Ningxia, Heilongjiang and so on, resulting in serious waste of energy and assets.

In order to improve the wind power utilization, the National Energy Bureau actively promoted the application of thermal energy storage technology to improve the output of wind power in limited conditions [2]. Caixia Wang did research on the economy of the wind power supply mode. According to the calculation principle, it can be known that there is a poor and single economic problem in the electric heating technology [3]. Currently, several domestic plants of electric heating with heat storage technology are enduring heavy financial losses, such as wind power clean heating pilot at Taonan Jilin. Therefore, it is necessary to analyze and evaluate the life cycle of electric heating with heat storage technology consuming abandoned wind, finding out the distinctions in environmental costs from thermoelectric unit, discussing the sustainability of electric heating by consumptive wind power from the view of environmental subsidy.

1. LCA principle and calculation model

1.1 LCA PRINCIPLE

The definition of life cycle assessment (LCA) is one of technologies and methods, compiling and evaluating the input, output and potential environmental impacts in the life cycle of a product system. It is applied to estimate the environmental effect of one product throughout the life cycle, including acquisition of raw materials, production, disposal after usage [4]. The LCA of electric heating with heat storage technology consuming abandoned wind and cogeneration heating mode, is defined to analyze and evaluate the resource consumption and environmental impact, depending on the basic data about resource consumption and pollutant emission from each stage of production chain. The LCA calculation model of electric heating with heat storage technology consuming abandoned wind is illustrated by the following image (Fig.1).




Fig.1 The LCA model of electric heating with heat storage technology consuming abandoned wind

1.2 ENVIRONMENTAL COST CALCULATION MODEL BASED ON LCA LIST

Based on the pollution calculated by LCA inventory analysis, environmental cost may convert into economic cost in accordance with the disposal cost of unit equivalent pollution. Environmental costs of each process can be calculated and allocated to unit product, making comparison among pollution costs of each product.

$$C_E = \sum_{j=1}^n C_{EE_j} + \sum_{j=1}^n C_{EF_j} + \sum_{j=1}^n C_{ET_j} + \sum_{j=1}^n C_{EI_j} + \sum_{j=1}^n C_{EO_j} + \sum_{j=1}^n C_{ED_j} \dots 1$$

In the formula,

- CE Environmental cost of heat storage electric heating boiler;
- C_{EEj} The environmental cost of the j pollutant in the material exploitation list of electric heating boiler with heat storage;
- C_{EFj} The environmental cost of the j pollutant in the list of manufacturing equipment for electric heating boiler with heat storage;
- C_{ETj} The environmental cost of the j pollutant in transportation list of electric heating boiler with heat storage;
- C_{EIj} The environmental cost of the j pollutant in installation

list of electric heating boiler with heat storage;

C_{EOj} The environmental cost of the j pollutant in function list of electric heating boiler with heat storage;

C_{EDj} The environmental cost of the j pollutant in dismantlement list of electric heating boiler with heat storage.

2. Data list and analysis of electric heating mode with heat storage technology consuming abandoned wind

2.1 LCA CALCULATION AND ANALYSIS OF THE NEW ELECTRIC HEATING SYSTEM

The full life cycle of electric heating boiler with heat storage function consists of many links, including construction, operation, maintenance, removal and so on. A electric heating boiler with heat storage function in China is chosen to be the objective for study, which contains two sets of 1440 kW automatic high temperature electric heating boilers with 98% conversion efficiency.

2.1.1 INVENTORY ANALYSIS OF ELECTRIC HEATING BOILER ROOM

The list of boiler room mainly consists of three sections: production list of building materials for electric boiler room construction, transportation list and building list of electric heating boiler room. The following analysis is aiming at the three parts.

(1) Inventory analysis of materials production for electric boiler room construction

According to the data of boiler room construction process, the type and quantity of building materials mainly consumed by the construction of boiler room are 6880kg steel, 33440kg cement and 67840kg brick [5-7]. Referring to the list of data in CLCD, calculation results of production list of building materials for electric boiler room construction are shown in Table 1.

(2) Inventory analysis of building materials transportation for electric heating boiler room

The total weight of building materials is 1.2 times the weight of the main building materials, totally 129792kg. The average transportation mileage is 25 kilometers by the medium sized gasoline trucks. After circulation of LCA data., transportation list of building materials for electric heating boiler room is shown in Table 2.

TABLE 1 PRODUCTION LIST OF BUILDING MATERIALS FOR ELECTRIC BOILER ROOM CONSTRUCTION

List items	Steel	Cement	Brick
CO	207.00	8.03	2.62
CO ₂	14610.37	3945.92	867.27
SO ₂	37.63	1.98	1.25
NO _x	31.68	8.83	8.12
COD	41.42	0.24	2.98
Slag	3716.58	67926.67	/

TABLE 2 TRANSPORTATION LIST OF BUILDING MATERIALS FOR ELECTRIC HEATING BOILER ROOM

List items	Environmental emissions (kg)				
	CO	CO ₂	SO ₂	NO _x	COD
Amount	2390.00	10981.00	28.74	161.42	53.29

(3) Inventory analysis of building the electric heating boiler room

The pollution from the construction of electric heating boiler room mainly consists of waste residue, waste water, and exhaust gas. After these measures, the quantity of pollution contains 25600kg waste water, 1600kg rubbish, and 629.6kg dust.

2.1.2 Inventory analysis of electric heating boiler

(1) Inventory analysis of materials production for electric heating boiler

Steel is the main material of electric heating boiler equipment, weighing 7700kg. Inventory analysis of materials production for electric heating boiler is shown in Table 3.

TABLE 3 PRODUCTION LIST OF BOILER EQUIPMENT MATERIALS

List items	Environmental emissions (kg)					
	CO	CO ₂	SO ₂	NO _x	COD	矿渣
Amount	231.77	16351.72	42.11	35.46	46.36	4159.54

(2) Inventory analysis of manufacturing electric heating boiler

In the boiler factory, firstly, the raw materials are cut by cutting machine or sheared by shearing machine. Then they need to be rolled, bent and stamped. Finally, they can be welded. After the completion of assembling boiler, there is flaw detection text to check cracks or defects. The products through inspection need water pressure test to check if these meet the technical requirement standard. Ultimately, these need to take a series of treatment measures, including removing rust, painting, packaging and so on.

Other main materials require in the manufacturing process of electric heating boiler are:

1. **The electrode:** according to the principle that the quantities of electrodes consumed per tonne steel is 25 kg, total electrodes are 0.19 tonnes;

2. **Paint:** the amount of paint consumed in manufacturing electric heating boiler is about 45 kg.

The environmental pollution in the manufacturing process of electric heating boiler mainly contains welding pollution and paint pollution [9]. The quantity of electrodes and paint respectively are 190kg, 45kg. The calculation results are shown in Table 4.

TABLE 4 POLLUTION LIST OF BOILER MANUFACTURING PROCESSES

List items	Environmental emission (kg)			
	CO	CO ₂	SO ₂	NO _x
Welding	8.17	3752.50	695.40	30.40
spray lacquer	0.23	34.62	5.16	0.98

(3) Inventory analysis of transportation of electric heating boiler

The transportation mileage of electric heating boiler takes an average of 25 kilometers. And medium-sized gasoline trucks' LCA data is selected for calculation. Transportation list of electric heating boiler is shown in Table 5.

TABLE 5 TRANSPORTATION LIST OF BOILER

List items	Environmental emissions (kg)				
	CO	CO ₂	SO ₂	NO _x	COD
Amount	141.76	651.43	1.71	9.58	3.16

(4) Inventory analysis of operation of electric heating boiler

Energy consumption of electric heating boiler is electricity. According to the boiler's rated power and the heating time in the whole life cycle, the power consumption in the whole life cycle can be calculated. Heating time takes an average of 122 days per year. Considering the efficiency of heating, The total electricity consumed by the electric heating boiler during the whole life cycle is 110GWh.

2.1.3 Inventory analysis of auxiliary equipment's material production of electric heating system

The auxiliary equipment list of electric heating system includes two parts: auxiliary equipment material production list and auxiliary equipment material transportation list. The inventory analysis of these two parts is as follows.

(1) Inventory analysis of auxiliary equipment's material production for electric heating system

The total consumption of auxiliary equipment for electric heating boiler room is the sum of auxiliary equipment consumption and pipe system consumption. The main auxiliary equipment and steel consumption of electric heating boiler is shown in Table 6. The list of auxiliary equipment material production is shown in Table 7.

(2) Inventory analysis of auxiliary equipment material transportation in electric heating system

The transportation mileage of electric heating boiler takes an average of 25 kilometers. Medium-sized gasoline trucks'

TABLE 6 STEEL CONSUMPTION OF MAIN AUXILIARY EQUIPMENT IN ELECTRIC BOILER ROOM AND THE BOILER ROOM PIPE SYSTEM

Name	Unit	Weight
Main auxiliary equipment for electric heating boiler room		
1 Plate heat exchanger	kg	3300
2 High temperature storage tank (heat preservation/anti corrosion/color steel plate)	kg	6700
3 Automatic water softener	kg	1700
4 Soft water tank	kg	800
Sub-total	kg	11000
Pipe system of electric heating boiler room		
5 Steel pipe	kg	8912
6 Elbow	kg	631
7 Flange	kg	308
8 Valve	kg	902
9 Steel plate	kg	12147
Sub-total	kg	22900
Total	kg	33900

TABLE 7 PRODUCTION LIST OF AUXILIARY EQUIPMENT MATERIALS IN ELECTRIC HEATING SYSTEM

List items	Environmental emissions (kg)				
	CO	CO ₂	SO ₂	NO _x	COD
Amount	1020.40	71990.00	185.42	156.00	204.09

LCA data is selected for calculation. Transportation list of auxiliary equipment material in electric heating system is shown in Table 8.

TABLE 8 TRANSPORTATION LIST OF AUXILIARY EQUIPMENT MATERIAL IN ELECTRIC HEATING SYSTEM

List items	Environmental emissions (kg)				
	CO	CO ₂	SO ₂	NO _x	COD
Amount	624.13	2867.97	7.51	42.16	13.92

2.1.4 The quantity list of unit heating in electric heating mode

According to the above analysis of the electric heating boiler room, electric heating boiler and auxiliary equipment of electric heating system, the quantity list of unit heating in electric heating mode is shown in Table 9.

TABLE 9 ELECTRIC HEATING MODE, HEATING UNIT, HEATING QUANTITY LIST OF HEATING METER

List items	Unit environmental emissions (kg/MJ)				
	CO	CO ₂	SO ₂	NO _x	COD
Amount	4.60×10^{-6}	1.95×10^{-4}	5.02×10^{-7}	5.36×10^{-7}	5.70×10^{-7}

2.2 ANALYSIS OF WIND POWER LIST

Several persons including Xiao Shao takes an onshore wind machine as an example, domestic ventas V90.3MW, calculating the environmental benefits of wind generator in the whole life cycle [10]; Weiguang Zhu takes the wind power plant called HaiWang Temple, located at Faku County;

ShenYang, for research objective to conduct the study. The results show that wind power can reduce the emission of 9.923 tonnes of carbon dioxide, 0.050 tonnes of NO_x and 0.079 tonnes of SO₂ into atmosphere every 10MWh electricity, compared to coal-fired power generation; Tremeac B utilizes LCA to make comparison between the two systems, 4.5MW and 250W wind turbine, to evaluate their impact on environment [9-11]. Based on the above research results and proportion of domestic wind power type, pollutant discharge of unit power generation of wind power generating is shown in Table 10.

TABLE 10 POLLUTANT DISCHARGE METER OF UNIT POWER GENERATION OF WIND POWER GENERATING

List items	Environmental emission (kg/MWh)			
	CO	CO ₂	SO ₂	NO _x
Amount	0.101	22.910	0.457	0.253

Note: the average loss rate of wind power transmission is 5.4%.

2.3 LCA LIST OF ELECTRIC HEATING MODE WITH HEAT STORAGE TECHNOLOGY CONSUMING ABANDONED WIND

Through summarizing the electric heating boiler room list, electric heating boiler list, auxiliary equipment list and wind power list, LCA list of electric heating model with heat storage technology consuming abandoned wind are shown in Table 11.

TABLE 11 LCA-LIST OF HEATING UNIT BY ELECTRIC HEATING BOILER WITH HEAT STORAGE TECHNOLOGY CONSUMING ABANDONED WIND

List items	Environmental emissions (kg/MJ)				
	CO	CO ₂	SO ₂	NO _x	COD
Amount	3.32×10^{-5}	6.68×10^{-3}	1.29×10^{-4}	7.22×10^{-5}	5.70×10^{-7}

3. Comparison of environmental cost between electric heating with heat storage technology and cogeneration heating mode

3.1 COMPARISON OF POLLUTANT EMISSIONS OF TWO HEATING MODES

The data list and analysis of cogeneration heating mode mainly include three sections: inventory analysis of boiler room, inventory analysis of boiler and inventory analysis of auxiliary equipment. According to the research results conducted by Junxiang Zhang, the LCA list of unit heating by cogeneration heating mode can be obtained [12-13]. The pollution discharge per heat from electric heating with heat storage technology and cogeneration heating model is respectively shown in Table 12.

3.2 COMPARISON OF ENVIRONMENT COST BETWEEN TWO HEATING MODES

According to the relevant provisions of “regulation for the collection of sewage charges” (the State Planning Commission, Treasury Department, the state environmental protection administration, economic and trade commission, the thirty-first orders in 2003) and “notice of the adjustment of the sewage fee collection standards and other related

TABLE 12 THE CONTRAST IN UNIT POLLUTANT EMISSIONS BETWEEN TWO HEATING MODES

List items	Pollutant emissions per heat (kg/GJ)		
	Electric heating with heat storage technology consuming abandoned wind	Cogeneration heating mode	
Environmental emission	CO	3.48×10^{-2}	3.69×10^{-2}
	CO ₂	7.06	17.00
	SO ₂	0.137	0.703
	NO _x	7.63×10^{-2}	0.143
	COD	5.70×10^{-4}	3.33

issues” (NDRC price [2014] No. 2008), the equivalent values of statistical pollutant including CO, CO₂, SO₂, NO_x, and COD are 16.7kg, 1kg, 0.95kg, 1kg, corresponding to the prices: 0.6 Yuan, 0.04 Yuan, 1.2 Yuan, 1.2 Yuan and 1.4 Yuan. Pollution equivalent value and environment cost of unit heating by two heating modes are shown in Table 13 [15, 16].

Note: the pollution equivalent value of a pollutant =
$$\frac{\text{The pollution missions (kg)}}{\text{Pollution equivalent of the pollutant (kg)}}$$

In addition, according to the average rate of coal ash 26% (coal power plant in accordance with the average 4000 kcal/kg) and ash utilization rate of 70%, the yield of fly ash per heat is about 12.8 kg/GJ. With the sewage charges of 30 Yuan/tonne, the pollution cost of coal ash per heat from cogeneration heating mode was 0.382 Yuan/GJ.

From the data in Table 13, it is obvious that the environment cost of unit heat by electric heating mode with heat storage technology consuming abandoned wind is significantly lower than that of cogeneration heating mode. Currently, the heating price in north China is generally around 28 Yuan/GJ. Table data displays that environmental cost of cogeneration heating mode is about 6.83Yuan/GJ, but environmental cost of electric heating mode with heat storage

TABLE 13 THE COMPARISON OF EQUIVALENT VALUE AND ENVIRONMENT COST OF UNIT HEATING BETWEEN TWO KINDS OF HEATING MODES

List items	Pollution equivalent of unit heat (Equivalent value/GJ)		Environment cost of unit heat (Yuan/ GJ)		
	Electric heating with heat storage technology consuming abandoned wind	Cogeneration heating mode	Electric heating with heat storage technology consuming abandoned wind	Cogeneration heating mode	
Environmental emission	CO	2.09×10^{-3}	2.21×10^{-3}	1.25×10^{-3}	1.33×10^{-3}
	CO ₂	7.43	17.9	0.297	0.716
	SO ₂	0.145	0.74	0.174	0.888
	NO _x	8.04×10^{-2}	0.151	9.64×10^{-2}	0.181
	COD	5.70×10^{-4}	3.33	7.98×10^{-4}	4.662
	Total	-	-	0.569	6.449

technology consuming abandoned wind is only 4.35 Yuan/GJ. Therefore, from the point of environmental cost, electric heating with heat storage technology consuming abandoned wind mode has obvious advantages in the economy and significant promotional worth.

4 Conclusions

Compared to the cogeneration heating mode, electric heating mode with heat storage technology consuming abandoned wind has obvious advantages, with low environment cost per heat. From the perspective of environmental protection, electric heating mode with heat storage technology consuming abandoned wind deserves to be widely promoted, especially in north areas where the phenomenon of abandoned wind is serious, which can consume wind power efficiently. What is more, environment pollution caused by electric heating mode with heat storage technology consuming abandoned wind is low.

Acknowledgements

Fund Project: research on the intelligent dispatching management theory of large scale clean energy generation in smart grid; Natural Science Foundation (71071052).

References

- [1] Liu, Q.C, Zhang, Q.Y. And Xu, X. (2012): Heat storing electric boiler application for energy storage and peak shaving to increase utilization rate of wind power capacity[J]. *Huadian Technology*, 34(9):75-82.
- [2] Pei, Z.Y., Fan, G.F. (2014):Research on wind power operation and accommodation problems in China[J]. *Electric Power*, 47(4):1-4.
- [3] Wang, C.X., Li, Q.H. And Xie, G.(2014): Pricing mechanism and economic analysis of heating supply by wind power[J]. *Electric Power*, 47(10): 156-160.
- [4] Frischknecht, R., Jungbluth, N. and Althaus (2007): Implementation of life cycle impact assessment methods [M], Swiss Centre for Life Cycle Inventories.
- [5] Yang, J.X., Liu, B.J. (2002): Life cycle inventory of steel products in China[J]. *Environmental Science Journal*. 22(4):519-522.
- [6] Michaeleb (2010): Identifying improvement potentials in cement production with life cycle assessment[J]. *Environmental Science and Technology*, (44):9143-9149.
- [7] Burgess, A., Brennan, D. J. (2001): Application of life cycle assessment to chemical processes. *Chemical Engineering Science*, (2):589-604.
- [8] Shao, X., Ju M.T. and Shao, C.F. (2012): Environmental Load of Wind Turbine in China Based on Life Cycle Assessment[J], *Ecological Economy*, 145-148.

- [9] Tremeac, B., Meunier, F.(2009): Life cycle analysis of 4.5MW and 250W wind turbines[J]. *Renewable and Sustainable Energy Reviews*, 8 (13): 2104-2110.
- [10] Crawford, R H. (2009): Life cycle energy and greenhouse emissions analysis of wind turbines and the effect of size on energy yield[J]. *Renewable and Sustainable Energy Reviews*, 8(13):2653- 2660.
- [11] Martinez, E., Sanz, F. and Pellegrini, S., et al. (2009): Life cycle assessment of a multi-megawatt wind turbine [J]. *Renewable Energy*, 34:667- 673.
- [12] Zhang, J.X., Zhu, G.F. (2014): Comparative study on life cycle assessment of photovoltaic and coal-fired power generation [J]. *Environmental Science and Management*, 39 (10): 86-90.
- [13] Su, Zhang, Yuan. (2010): Environmental performance of power generation system in China based on LCA[C]. AIP Conference Proceedings, 260-263.
- [14] Agarwal, G., Agarwal, K. K., & Roy, S. (2014). Investigations on physical and mechanical properties of short jute fiber reinforced epoxy composites. *Journal of Mechanical Engineering Research & Developments*, 37(2), 1-10.
- [15] Dorraj, S., M. B. Mojtaba, and A. A. Vafaie-Sefti. "Compressive, flexural and abrasive performance of steel fiber-reinforced concrete." *Journal of Mechanical Engineering Research & Developments* 37.1 (2014): 1-10.

MICROGRID: PROTECTION PROBLEMS FOR SMART ENERGY MANAGEMENT – A COMPREHENSIVE REVIEW

(Continued from page 70)

- [35] Ustun T. S., Ozansoy C., Zayegh A.: "Modeling of a centralized microgrid protection system and distributed energy resources according to IEC 61850-7-420", *IEEE Trans. Power Syst.*, vol. 27, no. 3, pp. 1560-1567, Aug. 2012.
- [36] Higgins N., Vyatkin V., Nair N.K.C., Schwarz K.: "Distributed power system automation with IEC 61850, IEC 61499, and intelligent control", *IEEE Trans. Syst., Man, Cybern. C, Appl. Rev.*, vol. 41, no. 1, pp. 81-92, Jan. 2011.
- [37] Kantarci M. E., Mouftah H. T.: "Energy-Efficient Information and Communication Infrastructures in the Smart Grid: A Survey on Interactions and Open Issues", *Commun. Surveys Tuts, IEEE*, vol.17, no.1, pp.179-197, 2015.
- [38] Parhizi S., Lotfi H., Khodaei A., Bahramirad S.: "State of the Art in Research on Microgrids: A Review", *IEEE Access*, vol. 3, pp. 890-925, 2015.
- [39] Salomonsson D, et al.: "Protection of low-voltage DC microgrids", *IEEE Trans on Power Deliv* 2009; 24:1045-53.
- [40] R. M. Cuzner and G. Venkataramanan, "The status of DC micro-grid protection", IEEE industry applications society annual meeting, pp. 1-8, 2008.
- [41] Monadi M., Gavriluta C., Luna A., Candela J.I., Rodriguez P.: "Centralized Protection Strategy for Medium Voltage DC Microgrids", *IEEE Transactions on Power Delivery*, Vol.32, No.1, pp. 430-440, Feb. 2017.

Indian Journal of Power & River Valley Development

Forthcoming International Conference on

ADVANCES AND CHALLENGES IN SUPERCRITICAL POWER GENERATION TECHNOLOGY

The Journal is planning to host an international conference sometime towards the end of this year at Kolkata. For details, please contact

The Editor & The Organising Secretary

International Conference

Indian Journal of Power & River Valley Development

(Conference Secretariat)

6/2 Madan Street, Kolkata 700 072

Phone : +91 33 22126526, Mob: +91 9239384829 / +91 8479919829 • Fax : 0091 33 22126348

E-mail: bnjournals@gmail.com / pradipchanda@yahoo.co.uk • Web: www.ijprvd.info